

APPENDIX-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1426.


Dated: 11/08/2026

It is certified that an inspection team headed by C.H.O. & A.N.M. Team, workers

From CHC Veerpura, Chandaus Aligarh (UP) inspected the Pathfield International School, Veerpura, Aligarh (UP)

on 11/08/2026 (date of inspection) and found that the Pathfield International School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central /State/U.T.Govt.

The above is valid for a period of two year

Signature with Seal: 
Name: Bhupendra Singh

Designation: C.H.O.

To,

Pathfield International School, Khair Road Veerpura, Aligarh (UP)

(Name & Address of the Institution)

PathField International School

Kaushan
Principal

Pathfield International School


Manager



Eko Pro Engineers Pvt. Ltd.

(EKO TESTING LABS)[®]

Competence | Quality | Service

Contact : +91 - 9810243870



Building Relations

ULR -TC420126500002037F

TEST REPORT

Water Sample Analysis

Test Report No. : EKO/W-505/270526

Issue Date : 01/06/2026

Issued To : PATH FIELD INTERNTIONAL SCHOOL
Aakash Educationturst
(Path Field, International School)
Vill- Veerpura, Gabhana, Aligarh, UP

Sample Description : Drinking Water
Sample Drawn on : NA
Sample Drawn by : Given By Client
Sample Received on : 27/05/2026
Sampling Location : NA
Sampling Plan & Procedure : NA
Sample Quantity : 1.0 Litre
Environmental Conditions : Normal
Analysis Duration : 27/05/2026 To 01/06/2026
Remark (if any) : NA

RESULTS

S. No.	Parameters	Test Methods	Results	Units	Limits as per IS:10500-2012	
					Acceptable	Permissible
1	Colour	IS: 3025 (Part-4) : 2021	BLQ (LOQ-1.0)	Hazen	5.0	15.0
2	Odour	IS: 3025 (Part-5): 2018	Agreeable	-	Agreeable	Agreeable
3	Taste	IS: 3025 (Part- 7): 2017	Agreeable	-	Agreeable	Agreeable
4	Turbidity	IS 3025 (P-10): 2023	BLQ (LOQ-1.0)	NTU	1.0	5.0
5	pH	IS: 3025 (Part-11): 2022	7.11	-	6.5-8.5	No relaxation
6	Total Hardness (as CaCO ₃)	IS: 3025 (P-21)(5): 2009	30.0	mg/L	200.0	600.0
7	Total Alkalinity (as CaCO ₃)	IS: 3025 (P-23): 2023	24.0	mg/L	200.0	600.0
8	Chloride (as Cl)	IS: 3025 (Part - 32)(2):1998	35.5	mg/L	250.0	1000.0
9	Residual Free Chlorine	IS:3025 (Part- 26): 2021	BLQ (LOQ-0.1)	mg/L	0.2	1.0
10	Fluoride (as F)	IS : 3025 (Part-60): 2008	BLQ (LOQ-0.1)	mg/L	1.0	1.5
11	Total Dissolved Solids	IS: 3025 (Part-16): 2023	110.0	mg/L	500.0	2000.0
12	Total Coliform	IS: 15185: 2016	Not Detected	Per 100ml	Absent	-

Notes:

- The results given above are related to the tested sample, as received & mentioned parameters.
The customer asked for the above tests only.
- This test report will not be generated again, either wholly or in part, without prior written permission of the Laboratory.
- The test samples will be disposed off after 15 days from the date of issue of test report, unless until specified by the customer. Sample received for biological tests will be destroyed after 7 days from the date of issue of test report.
- Responsibility of the Laboratory is limited to the invoiced amount only.
- BLQ=Below Limits of Quantification, LOQ= Limits of Quantification

****End of Report****

For EKO PRO ENGINEERS PVT. LTD.
SHIVANGI SINGH RAIZADA
SECTION INCHARGE MICROBIOLOGY
(Authorised Signatory)

Principal

PathField International School

PathField International School

Principal

For EKO PRO ENGINEERS PVT. LTD.
PURNIMA CHAUDHAN
TECHNICAL MANAGER
(Authorised Signatory)

Pathfield International School

Manager

Page 1 of 1